

To: Johnstone, Jeremy[Johnstone.Jeremy@epa.gov]; Lawrence, Kathryn[Lawrence.Kathryn@epa.gov]; Proboszcz, Angie[Proboszcz.Angie@EPA.GOV]; Wesling, Mary[Wesling.Mary@epa.gov]
From: Moezzi, Rameen
Sent: Mon 6/2/2014 11:47:34 PM
Subject: FW: Hazardous Materials Spill Report: Cal OES Control #:14-3126

-----Original Message-----

From: Warning Center [mailto:Warning.Center@ops.calema.ca.gov]
Sent: Monday, June 02, 2014 4:19 PM
To: R9_RRC
Subject: Hazardous Materials Spill Report: Cal OES Control #:14-3126

Governor's Office of Emergency Services
Hazardous Materials Spill Report

DATE: 06/02/2014 | RECEIVED BY Cal OES: Tracy Stocks | Cal OES CNTRL #:14-3126
TIME: 1609 | RECEIVED BY OSPR: | NRC#:

1.a. PERSON NOTIFYING Cal OES

1. NAME: Ex. 6 - Personal Privacy 2. AGENCY: Mojave Solar
3. PHONE #: Ex. 6 - Personal Privacy 4. EXT: | 5. PAGER #:

1.b. PERSON REPORTING SPILL (If different from above):

1. NAME: | 2. AGENCY:
3. PHONE #: | 4. EXT: | 5. PAGER #:

2. SUBSTANCE TYPE:

a. SUBSTANCE: / b.QTY: / Amount / Measure / c. TYPE / d. OTHER / e. PIPELINE / f. Vessel Over => 300 tons

1. HTF, Heat Transfer Fluid / = / 28 / Gal(s) / CHEMICAL / / No / No

2.

3.

g. DESCRIPTION: RP states that a valve was left opened during the filling of HTF causing the release. Cleanup has been completed.

h. CONTAINED: Yes | i. WATER INVOLVED: No

j. WATERWAY: | k. DRINKING WATER IMPACTED:

l. KNOWN IMPACT: None

3.a. INCIDENT LOCATION: 42134 Harper Lake Rd

b. CITY: Hinkley | c. COUNTY: San Bernardino County | d. ZIP: 92347

4. INCIDENT DESCRIPTION:

a. DATE: 5/29/2014 | b. TIME(Military): 1020 | c. SITE: Other | d. CAUSE: Human Error e.
INJURIES: No | f. FATALITY: No | g. EVACUATIONS: No | h.
CLEANUP BY: Responsible Party
e. INJURIES #: | f. FATALS #: | g. EVACS #:

5. SUSPECTED RESPONSIBLE PARTY:

a. NAME: | b. AGENCY: Abeinsa EPC
c. PHONE#:
e. MAIL ADDRESS:
f. CITY: Hint:

Ex. 6 - Personal Privacy

6. NOTIFICATION INFORMATION:

a. ON SCENE: ☐ | b. OTHER ON SCENE: ☐
c. OTHER NOTIFIED: ☐
d. ADMIN. AGENCY: San Bernardino County Fire Department e. SEC. AGENCY:
f. ADDITIONAL COUNTY: g. ADMIN. AGENCY:
h. NOTIFICATION LIST: DOG Unit: | RWQCB Unit: 6B

AA/CUPA, DFG-OSPR, DTSC, RWQCB, US EPA, USFWS

Created by Warning Center on 6/2/2014 4:09:36 PM Last
Modified by Warning Center on 6/2/2014 4:19:07 PM

California State Warning Center
Governor's Office Emergency Services
Phone: (916) 845-8911
Warning.Center@oes.ca.gov

Link to Spill Report:

<http://w3.calema.ca.gov/operational/mal haz.nsf/SpillAllDocs/213F005392C18F7E88257CEB007F38FF?OpenDocument>